



**CITY OF FRIENDSWOOD
FIRE MARSHAL'S OFFICE**

1600 Whitaker Drive, Friendswood, TX 77546

281-996-3335

Friendswood.com

FIRE SPRINKLER SYSTEMS REPAIR REQUIREMENTS—FEBRUARY 2021

1. A [City permit](#) is required and can be obtained through Community Development at 281-996-3201. If this repair is due to frozen pipes or connections, there will be no charge.
2. Copies of the company license and technicians' licenses that will be installing or working on the system shall be submitted for review.
3. A letter as to the scope of the repairs shall be submitted for review. Please note: In certain circumstances, three (3) full sets of plans may be required.
4. A copy of liability insurance shall be submitted for review.
5. A Hydrostatic Test is required before the system is allowed to be put into service.
6. Shall follow [National Fire Protection Association \(NFPA\) 13 2019 edition](#), including Chapter 27 Plans and Calculations.